
SCC901 - RECOMMENDED SPECIFICATION**GENERAL**

Furnish and install where indicated on plans or described in schedules Storm Class[™] Louver Type SCC901 as designed and manufactured by The Aiolite Company LLC, Schofield, Wisconsin. Louvers shall be furnished with bird screen, insect screen, supports, installation hardware and finishes as specified and as required for a complete installation.

SUBMITTALS

Manufacturer shall submit shop drawings incorporating key plans, elevations, sections and details showing profiles, angles and spacing of louver blades and frames; unit dimensions related to wall openings and construction; and, anchorage details and locations. Provide samples of manufacturer's finish and color charts showing the full range of colors available. For each type of product specified, submit free area, air performance, water penetration and wind-driven rain ratings determined in accordance with AMCA Standard 500-L and licensed under the AMCA Certified Ratings Program.

PRODUCTS

Louvers shall be Storm Class[™] type and rated to resist water penetration under wind-driven rain conditions. Louvers shall be 9.25-inches (235.3 mm) deep and assembled entirely from extruded aluminum components. Exterior blades and frames shall be 0.081-inch (2 mm) thick extruded aluminum, alloy 6063-T5. Interior blades shall be 0.060-inch (1.5 mm) extruded aluminum, alloy 6063-T5. Exterior blades shall be horizontal and spaced 4.5-inches (114.3 mm) on center.

STRUCTURAL DESIGN CRITERIA

Manufacturer shall design and furnish all supports required to withstand a wind force of not less than 25 pounds per square foot. Louvers larger than 60-inches (152 cm) wide x 120-inches (305 cm) high will be fabricated and installed in multiple sections. Louver blades, frames, mullions and anchorages shall be demonstrated to withstand the specified wind design load.

PERFORMANCE RATINGS

FREE AREA:	866 Square Feet (0.80 m ²)
MINIMUM FREE AREA VELOCITY	
at Beginning Point of Water Penetration:	974 fpm (4.95 m/s)
MINIMUM AIR VOLUME FLOW RATE	
at Beginning Point of Water Penetration:	8,435 cfm (3.98 m ³ /s)
MAXIMUM STATIC PRESSURE	
at Beginning Point of Water Penetration:	0.32 in. H ₂ O (0.080 kPa)