



— Factory Piping
 - - - Field Piping by Others

Controller/Actuator - KMC CSP-4702
 Thermostat - KMC CTE-5202
 Transformer - 40 VA Min.

WARNING: 24V circuit is dedicated, Do not add or connect other items.

BPCD 360

(CDS) ATU\CONTROL DIAGRAMS\ANALOG

Phone: 715.359.6171
 Fax: 715.355.2399
 Parts : 800.355.5354
 gfcinfo@greenheck.com
 www.greenheck.com

N/A	F	Removed logo	7/12/21	CG
N/A	E	Removed A11 Wire	10/02/20	CG
N/A	D	UPDATED TO NEW FORMAT	08/30/17	RML
N/A	C	Rev. Control & Stat.	6/9/17	DSG
ECN. No.	Rev	Description	Date	Rev'd By:

Unless Otherwise Specified:
 1. Dimensions Are In Inches.
 2. Tolerances Are:
 Fractions Decimals Angles
 ±1/32 ±.X = .1 ±1°
 ±.XX = .02 ±.XXX = .010

Control Wiring Diagram

Bypass Air Terminal Unit
 Cooling Only VAV or CV

DWN. BY	DSG	DATE	07/22/08	DWG. NO.		REV.	
CHK'D BY	DSG	SCALE	NTS	BPCD360		F	