



——— Factory Piping  
 - - - Field Piping By Others

Controller/Actuator-CSP-4702, 24 VAC, 4 VA  
 Thermostat-CTE-5202

**Transformer Options:**  
 961E, - Primary Voltage to match electric heat / 24

- Notes:
- Maximum connected 24 Vac load connections not to exceed 20 VA

**FCCD 961E-SCR**  
**(CDS) ATU\CONTROL DIAGRAMS\ANALOG\**

# Control Wiring Diagram

**FAN POWERED AIR TERMINAL UNIT  
 COOLING WITH SCR ELECTRIC HEAT**

Unless Otherwise Specified: 1. Dimensions Are In Inches. 2. Tolerances Are: Fractions    Decimals    Angles $\pm 1/32$ $\pm .X = .1$ $\pm 1^\circ$ $\pm .XX = .02$ $\pm .XXX = .010$				<b>Control Wiring Diagram</b>	
DWN. BY DSG		DATE 10/14/02		DWG. NO.	
CHK'D BY		SCALE NTS		FCCD961E-SCR	
REV. K					

N/A	K	Removed logo	7/12/21	CG
N/A	J	UPDATED TO NEW FORMAT	07/26/17	RML
N/A	I	REVISED THERMOSTAT	4/16/15	DSG
ECN. No.	Rev	Description	Date	Rev'd By: