



—— Factory Piping
 - - - Field Piping By Others

Controller/Actuator-CSP-4702, 24 VAC, 4 VA

Thermostat-CTE-5202

Reheat Module-REE-5002, 24 VAC

Relays SPDT - HCR-51CQ1AC112 or Equiv.

Note : Do not interconnect 24V transformer secondary circuits.

Notes:
 *If HW Coil Then Valve and Heat 1 Wiring Field Installed

Transformer Options:

- 861N, - No Xformer
- 861A, - 120 / 24
- 861C, - 277 / 24
- 861F, - 240 / 24
- 861E, - Primary Voltage to match electric heat / 24

FVCD864-MW-AUTO

(CDS) ATU\CONTROL DIAGRAMS\ANALOG\

Control Wiring Diagram

AUTO MORNING WARM-UP
 FAN AND UP TO 3 STEPS REHEAT

Phone: 715.359.6171
 Fax: 715.355.2399
 Parts : 800.355.5354
 gfcinfo@greenheck.com
 www.greenheck.com

N/A	D	Removed logo	7/14/21	CG
N/A	C	UPDATED TO NEW FORMAT	06/19/17	RML
N/A	B	Revised C/O Stat	5/09	DSG
N/A	A	Added Stage #3	2/07	DSG
ECN. No.	Rev	Description	Date	Rev'd By:

Unless Otherwise Specified:
 1. Dimensions Are In Inches.
 2. Tolerances Are:
 Fractions Decimals Angles
 $\pm 1/32$ $\pm .X = .1$ $\pm 1^\circ$
 $\pm .XX = .02$
 $\pm .XXX = .010$

DWN. BY DB
 CHK'D BY DB

DATE 11/20/02
 SCALE NTS

DWG. NO.
 FVCD864-MW-AUTO

REV.
 D