



— Factory Piping  
 - - - Field Piping by Others

Controller/Actuator-CSP-4702, 24 VAC, 4 VA  
 Thermostat-CTE-5202  
 Reheat Module-REE-5002, 24 VAC  
 Relays SPDT - HCR-51CQ1AC112 or Equiv.

Note : Do not interconnect 24V transformer secondary circuits.

Notes:  
 \*If HW Coil Then Valve and Heat 1 Wiring Field Installed

Transformer Options:  
 861N, - No Xformer  
 861A, - 120 / 24  
 861C, - 277 / 24  
 861F, - 240 / 24  
 861E, - Primary Voltage to match electric heat / 24

### FVCD864-MW-AUTO

### (CDS) ATU\CONTROL DIAGRAMS\ANALOG\

# Control Wiring Diagram

AUTO MORNING WARM-UP  
 FAN AND UP TO 3 STEPS REHEAT

Phone: 715.359.6171  
 Fax: 715.355.2399  
 Parts : 800.355.5354  
 gfcinfo@greenheck.com  
 www.greenheck.com

N/A	D	Removed logo	7/14/21	CG
N/A	C	UPDATED TO NEW FORMAT	06/19/17	RML
N/A	B	Revised C/O Stat	5/09	DSG
N/A	A	Added Stage #3	2/07	DSG
ECN. No.	Rev	Description	Date	Rev'd By:

Unless Otherwise Specified:				
1. Dimensions Are In Inches.				
2. Tolerances Are:				
Fractions	Decimals	Angles		
±1/32	±.X = .1	±1°		
	±.XX = .02			
	±.XXX = .010			
DWN. BY	DB	DATE	11/20/02	DWG. NO.
CHK'D BY	DB	SCALE	NTS	FVCD864-MW-AUTO
				REV.
				D