
REVISION
 SYM

 --- 2



ITEM:

- 1. UL CLASSIFIED FIRE DAMPER DYNAMIC OR STATIC
 - 1.1. 1-1/2 HR. LABEL FOR FIRE SEPARATIONS LESS THAN 3 HOURS.
- 1.2. 3 HR. LABEL FOR FIRE SEPARATIONS GREATER THAN 3 HOURS (MODEL DFD-350)
- 2. FIRE SEPARATION
- 3. RETAINING ANGLES
- 4. BREAKAWAY JOINT
- 5. SLEEVE (DUCT GAUGE MIN. SMACNA/NFPA 90A SEPC.)
- 6. EXPANSION CLEARANCE
- 7. UL LISTED HEAT RESPONSIVE DEVICE (RRL, RRL/OCI, TOR)
- 8. DUCT
- 9. ACCESS DOOR (NFPA 80)
- 10. B TYPE TRANSITION

NOTE:

- DAMPERS SHALL BE CONSTRUCTED, TESTED, LABELED AND INSTALLED IN ACCORDANCE WITH UL 555, NFPA 80, NFPA 90A, NFPA 101 AND DAMPER MANUFACTURER'S INSTALLATION INSTRUCTIONS.
- RATED BARRIER SHALL MEET THE REQUIREMENTS OF INTERNATIONAL BUILDING CODE (IBC) AND COMPLY WITH LOCAL CODE REQUIREMENTS.
- 2.1. DAMPERS SHALL BE RATED FOR VERTICAL OR HORIZONTAL MOUNTING AS REQUIRED AND SHOWN ON PROJECT PLANS.
- 3. DAMPER OPENING (EXPANSION GAPS) SHALL BE PER DAMPER MANUFACTURER'S UL APPROVED INSTALLATION INSTRUCTIONS.
- 4. MAXIMUM DAMPER OPENING MAY NOT EXCEED THE DAMPER MANUFACTURER'S MAXIMUM UL LISTED SIZE.
- SLEEVE GAUGE, TERMINATIONS AND RETAINING ANGLES SHALL BE AS REQUIRED AND COMPLY WITH UL AND SMACNA REQUIREMENTS.
- CLOSURE DEVICE SHALL BE A UL LISTED FUSIBLE LINK AND COMPLY WITH THE REQUIREMENTS OF NFPA 80 AND THE INTERNATIONAL BUILDING CODE (IBC).
- 7. ACCESS DOORS SHALL BE PROVIDED FOR INSPECTION, TESTING AND MAINTENANCE TO COMPLY WITH NFPA 80.
- PROVIDE B TYPE TRANSITIONS ON ALL FIRE DAMPERS, EXCEPT WHERE DUCT TERMINATES AS A GRILLE. PROVIDE STANDARD A TYPE CURTAIN DAMPERS OR B TYPE OUT OF PARTITION DAMPERS WHERE DUCT TERMINATES AT A GRILLE.
- BASIS OF DESIGN SHALL BE GREENHECK DFD-150 1-1/2 HOUR, DYNAMIC RATED STEEL CURTAIN STYLE FIRE DAMPER. (ALTERNATE MODELS: DFD-110 1-1/2 HOUR RATED; DFD-310 3-HOUR RATED; DFD-350 3-HOUR RATED)

Copyright ® 2025 Greenheck Fan Corporation

Greenheck Fan Coporation reserves the right to make product changes without notice

