

ITEM:

- 1. UL CLASSIFIED FIRE DAMPER DYNAMIC OR STATIC
- 1.1. 1-1/2 HR. LABEL FOR FIRE SEPARATIONS UP TO 2 HRS.
- 1.2. 3 HR. LABEL FOR FIRE SEPARATIONS UP TO 4 HRS.
- 2. FIRE SEPARATION
- 3. MOUNTING FLANGE (VERTICAL INSTALLATION ONLY, RETAINING ANGLES REQUIRED FOR HORIZONTAL INSTALLATION)
- 4. BREAKAWAY JOINT
- SLEEVE "A TYPE TRANSITION" (DUCT GAUGE MIN. SMACNA/NFPA 90A SEPC.)
- 6. EXPANSION CLEARANCE
- 7. UL LISTED HEAT RESPONSIVE DEVICE (UL LISTED FUSIBLE LINK)
- 8. DUCTWORK
- 9. GRILLE

NOTE

- 1. DAMPERS SHALL BE CONSTRUCTED, TESTED, LABELED AND INSTALLED IN ACCORDANCE WITH UL555, NFPA 80, NFPA 90A, NFPA 101 AND DAMPER MANUFACTURER'S INSTALLATION INSTRUCTIONS.
- DAMPER RATING SHALL MEET THE REQUIREMENTS OF INTERNATIONAL BUILDING CODE (IBC) AND COMPLY WITH LOCAL CODE REQUIREMENTS.
- 2.1. DAMPERS SHALL BE RATED FOR VERTICAL OR HORIZONTAL MOUNTING AS REQUIRED AND SHOWN ON PROJECT PLANS.
- 3. DAMPER OPENING (EXPANSION GAPS) SHALL BE PER DAMPER MANUFACTURER'S UL APPROVED INSTALLATION INSTRUCTIONS.
- 4. MAXIMUM DAMPER OPENING MAY NOT EXCEED THE DAMPER MANUFACTURER'S MAXIMUM UL LISTED SIZE.
- 5. SLEEVE GAUGE, TERMINATIONS AND RETAINING ANGLES SHALL BE AS REQUIRED AND COMPLY WITH UL AND SMACNA REQUIREMENTS.
- 6. CLOSURE DEVICE SHALL BE A UL LISTED FUSIBLE LINK AND COMPLY WITH THE REQUIREMENTS OF NFPA 80 AND THE INTERNATIONAL BUILDING CODE (IBC).
- 7. PROVIDE A TYPE TRANSITIONS ON ALL IN BARRIER FIRE DAMPERS WHERE DUCT TERMINATES AS A GRILLE.
- 8. BASIS OF DESIGN SHALL BE GREENHECK DFD-150 1-1/2 HOUR, DYNAMIC RATED STEEL CURTAIN STYLE FIRE DAMPER. (ALTERNATE MODELS: DFD-110 1-1/2 HOUR RATED; SSDFD-150 1-1/2 HOUR RATED; DFD-310 3-HOUR RATED; DFD-350 3-HOUR RATED; SSDFD-350 3-HOUR RATED)

Copyright ® 2024 Greenheck Fan Corporation

LENGTH

6 INCH

MAX

(152mm)

Greenheck Fan Coporation reserves the right to make product changes without notice



REVISION

MARKETING NOTE UPDATES (8) , COPYRIGHT NOTE